



SAMALESWARI REGIONAL CO-OPERATIVE MILK PRODUCERS' UNION LTD.

Regd. No.6/SM of 6th March 76

GOSHALA, BOUDIAPADA, PO : KALAMATI, DIST-SAMBALPUR (ODISHA) 768 025

Phone : (0663) 2548590, 2950426, Mob.9437122477, GST NO.21AAMAS3215Q1Z8

Website : samul.in, E-mail : omfedsrmpul@gmail.com

Ref. No: SAMUL/635.

Dated - 30.09.2024

QUOTATION/TENDER CALL NOTICE

Sub : INVITATION FOR QUOTATIONS FOR SUPPLY OF SPARE PARTS FOR ETP (EFFLUENT TREATMENT PLANT)

You are invited to submit your most competitive quotation for the following goods -

Brief Description of the Goods	Specifications & Make & Model	Qty	Delivery Period	Place of Delivery	Installation Requirement if any
Spare Parts for 5 KLD ETP (Effluent Treatment Plant) on Turnkey basis	SPECIFICATION : Attached in Annexure-I	Mentioned in the attached sheet.	15 days	Milk Chilling Plant, Bargarh	Yes

- *Where ISI certification marked goods are available in market, purchase should generally be limited to goods with those or equivalent marking only.*
1. Interested Manufacturer/Supplier/Distributor may quote their rate indicating Make, Model, Price, Tax., Terms of Rate, Guarantee etc to the above address. **The detail technical specification, features of the Goods Make & Model should be clearly mentioned in the quotation.** Boucher/Leaflet of the goods be attached with the quotation.
 2. GST extra or inclusive should be clearly specified.
 3. Quotation should remain valid for a period not less than 60 days after the deadline date specified of submission.
 4. Quotation should conform to the terms and conditions, and specifications.
 5. Notwithstanding the above, the Purchaser reserves the right to accept or reject any quotations and to cancel the bidding process and reject any or all quotations at any time prior to the award of contract.
 6. Payment shall be made within 30 days of delivery of the goods.
 7. Warranty/ guarantee of the goods should be clearly specified in the offer letter.
 8. Term of supply i.e regarding Packing & forwarding, Insurance, Delivery period and term of delivery should be clearly mentioned.
 9. Quotation should reach latest by 15:00 hrs. on **dt.15.10.2024** for our consideration.
 10. All disputes are subject to Sambalpur jurisdiction.


General Manager



SAMALESWARI REGIONAL CO-OPERATIVE MILK PRODUCERS' UNION LTD.

Regd. No.6/SM of 6th March 76

GOSHALA, BOUDIAPADA, PO : KALAMATI, DIST-SAMBALPUR (ODISHA) 768 025

Phone : (0663) 2548590, 2950426, Mob.9437122477, GST NO.21AAMAS3215Q1Z8

Website : samul.in, E-mail : [omfedsrmpul@gmail.com/](mailto:omfedsrmpul@gmail.com)

Annexure – I

TECHNICAL SPECIFICATION FOR SPARE PARTS OF ETP (EFFLUENT TREATMENT PLANT)

Sl.No.	Item	Technical Specifications	Qty.
1.	Coarse Bar Screen	Size : 600 X 600 mm. Spacing : 3 mm. MOC : SS, Make : AWTP	1 No.
2.	Raw Sewage Transfer Pumps	Type : Submersible Capacity : 5 m ³ /Hr. Head : 6-10 m. Motor Rating : 2.2 KW MOC : CI Qty. : 1 Nos. (1 W + 1 S) Make : Kirloskar/Cri	1 No.
3.	Air Blowers	Type : Twin Lobe Compressor consist of V-belt, Drive and Driven Pulleys Capacity : 40 m ³ /hr. @ 0.4 Kg./cm ² MOC : Cast Iron Drive : Belt Driven Type Accessories : Base frames, Air filter for suction line and silencer for discharge, safety valve & Pr.Gauge, V belt, V belt guard Make : Akash MOTOR Type : Horizontal Foot Mounted motor Qty. 1 No. (1 W + 1 S) Make : ABB/Cromton	1 No.
4.	Coarse Bubble Diffusers	Type : Coarse Bubble Diffusers Size : 80 mm. disc. MOC : EPDM Membrane Make : Scogen/KCS	8 Nos.
5.	Fine Bubble Diffusers	Type : Fine Bubble Size : 90 mm. Dia X 1000 mm. Long MOC : EPDM Membrane Make : Scogen/KCS	8 Nos.
6.	Sludge Transfer Pump	Type : Self Priming Capacity : 8 m ³ /hr. Head : 8-12 m. Motor Rating : 0.75 KW MOC : CI Make : Kirloskar Sp0.5 hm.	1 No.
7.	Filter Feed Pumps	Type : Centrifugal monobloc Capacity : 6 M ³ /Hr. Head : 8-10 m. Motor Rating : 2.2 KW MOC : CI Qty. : 1 Nos. (1 W + 1 S) Make : Kirloskar/Algo	2 Nos.

7/11/2024



SAMULES WARI REGIONAL CO-OPERATIVE MILK PRODUCERS' UNION LTD.

Regd. No.6/SM of 6th March 76

GOSHALA, BOUDIAPADA, PO : KALAMATI, DIST-SAMBALPUR (ODISHA) 768 025

Phone : (0663) 2548590, 2950426, Mob.9437122477, GST NO.21AAMAS3215Q1Z8

Website : samul.in, E-mail : [omfedsrempul@gmail.com/](mailto:omfedsrempul@gmail.com)

Sl.No.	Item	Technical Specifications	Qty.
8.	Pressure Sand Filter	Type : Frp Capacity : 5 M ³ /Hr. Size : 13 X 54 mm. Filter Media : Graded Sand & Pebbles of various sizes Qty. Of media : 100 Kg. Supporting media Make : Awtp	1 No.
9.	Activated carbon Filter	Type : Frp Capacity : 5 M ³ /Hr. Size : 13 X 54 mm. Filter Media : Carbon and Pebbles Qty. Of media : 60 Kg. Supporting media : 20 Kg. (Pebbles Make : Awtp	1 No.
10.	Hypo dosing system	Capacity : 0-5 LPH at 3.0 Kg./cm ² MOC : PP Dosing Tank Volume : 100 Ltrs. MOC of Tank : HDPE Make : EDose – sintex/Eq	1 No.
11.	Inter Connecting Piping Valves & Accessories	Supply, Installation, Testing & Commissioning of all Piping within the plant necessary to the treatment plant. MS B Class Piping : Jindal/Eq UPVC Piping : Finolex/Supreme/Eq MOC of Valves : Inter Valve/Eq	1 Lot
12.	Control Panel	Supply, Installation, Testing and commissioning of compartmentalized Starter Make : Power Max/KCS/Enrun/Eq	1 No.
13.	Frp Tank Sbr	5 mm. Thick height 8 ft. Leant 7 ft.	1 No.

13/4/20